



CONCRETE GRADE BEAM DETAIL

NTS

NOTES:

1. THIS ITEM MAY BE PRECAST OR CAST IN PLACE.
2. CONCRETE TO BE CLASS A3 IF CAST IN PLACE, 4000 PSI IF PRECAST.
3. THE PICP PAVER SHALL BE INSTALLED AT LEAST 1/4" AND NO MORE THAN 3/8" ABOVE THE ADJACENT CONCRETE GRADE BEAM TO ALLOW FOR ANY FUTURE SETTLEMENT THAT MAY OCCUR.
4. THE DEPTH OF THE CURB MAY BE REDUCED AS MUCH AS 3" (15" DEPTH) OR INCREASED AS MUCH AS 3" (21" DEPTH) IN ORDER THAT THE BOTTOM OF CURB WILL COINCIDE WITH THE PAVEMENT SUBSTRUCTURE. OTHERWISE, THE DEPTH IS TO BE 18" AS SHOWN. NO ADJUSTMENT IN THE PRICE BID IS TO BE MADE FOR A DECREASE OR AN INCREASE IN DEPTH.

MODIFICATIONS OF DRAWINGS ARE ONLY PERMITTED
BY WRITTEN AUTHORIZATION FROM EAGLE BAY

DATE: 05-01-15

DWG: 4 OF 14