



PLAN VIEW  
NTS

NOTES:

1. THIS ITEM MAY BE PRECAST OR CAST IN PLACE.
2. CONCRETE TO BE CLASS A3 IF CAST IN PLACE, 4,000 PSI IF PRECAST.
3. CURB OPENING DIMENSION SHOWN IS A MINIMUM. CURB CUT SHALL BE SIZED TO CONVEY THE WATER QUALITY STORM (OFFLINE) OR TO CONTROL SPREAD IN THE GUTTER PAN (ONLINE) PER STANDARD ENGINEERING METHODS.
4. THE DEPTH OF THE CURB CUT MAY BE REDUCED AS MUCH AS 3" (15" DEPTH) OR INCREASED AS MUCH AS 3" (21" DEPTH) IN ORDER THAT THE BOTTOM OF CURB WILL COINCIDE WITH THE TOP OF A COURSE OF THE PAVEMENT SUBSTRUCTURE. OTHERWISE THE DEPTH IS TO BE 18" AS SHOWN. NO ADJUSTMENT IN THE PRICE BID IS TO BE MADE FOR A DECREASE OR AN INCREASE IN DEPTH.

MODIFICATIONS OF DRAWINGS ARE ONLY PERMITTED  
BY WRITTEN AUTHORIZATION FROM EAGLE BAY

DATE: 05-01-15

DWG: 5 OF 14