



DEPARTMENT OF PERMITTING SERVICES

Isiah Leggett  
County Executive

June 3, 2013

Diane R. Schwartz Jones  
Director

Mr. Don Tapley  
Eagle Bay Hardscape Products  
1231 Willis Road  
Richmond, VA 23237

Re: Aqua-Bric type 4 "L"

Dear Mr. Tapley:

Please be advised that the Stormwater Management New Products and Materials Committee for Montgomery County **recommends** the above mentioned product for use in Montgomery County.

The approval is based on the following conditions.


1. This approval is valid for a period not to exceed five years. Manufacturer must reapply for approval to continue use of this product prior to the end of the five year period or the product will no longer be acceptable for use.
2. Shop drawings for each unit must be reviewed and approved by the design engineer for dimensions, structural integrity, and overall conformance with the approved stormwater management plans and Montgomery County standards (including ACI-350 for concrete). Shop drawings must be submitted for review and approval by the design engineer and for acceptance by DPS prior to fabrication.
3. All structures must adhere to current DPS access guidelines.
4. Structures within the Public Right of Way must be approved by the Montgomery County Department of Transportation and the Department of Permitting Services, Right of Way Section.
5. This product is approved as a permeable pavement and is subject to the design standards for permeable pavements that are outlined in Chapter 5 of the Maryland Stormwater Management Design Manual.

6. This product must also comply with the most current Montgomery County design specifications for permeable pavements.
7. The manufacturer must provide any special design considerations where soil bearing stability may be a concern.

All changes and/or modifications to the approved design parameters for this product must be submitted to the County for approval prior to use in the County. Failure to do so will result in revocation of this approval.

If you have questions or comments please contact me at 240-777-6338.

Sincerely,



Mark C. Etheridge  
Manager

cc: William Campbell  
Tom Weadon